

Material &amp; Engineering Laboratory-Taichung

## TEST REPORT



Report No.:TK-16-03179X

Page : 1 OF 1

Date :Jul. 01, 2016

Project Overseas Projects  
Applicant WECAND ENTERPRISE CO., LTD  
Product Description O.D:114.3mm Steel pipe  
(for Tunnel umbrella pipe roof method)  
Steel grade:S275 J0H  
Received Date Jun. 16, 2016  
Tested Date Jun. 16, 2016~Jun. 20, 2016  
Specifications requirement EN 10219-1:2006 Grade. S275J0H  
Test Method EN 10002-1:2002  
Remark The information mentioned in the above section is provided by Client  
(Exclude Date of Sample Received and Date of Testing)

## Test Result:

Sample Name	0.2%offset Yield strength	Tensile strength	Elongation (G.L=50mm)
----	MPa	MPa	%
Steel pipe	345	451	36
Spec's requirements	≥ 275	410~560	≥ 20

----- oOo -----

For and on behalf of  
WECAND ENTERPRISE CO., LTD.

.....  
Authorized Signature(s)

The required specification(s) offered in this test report is/are for reference only.  
The conformity judgment is at the Applicant's final verdict.

Signed for and on behalf of  
SGS TAIWAN Ltd.

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.