

TEST REPORT



Report No.:TK-15-05757XA

Page : 1 OF 1

Date :Nov.03, 2015

Applicant WECAND ENTERPRISE CO., LTD
Product Description GFRP Rock Bolt
Product Type R32 Hollow Rod×1
Received Date Nov. 02, 2015
Tested Date Nov. 02, 2015~Nov. 03, 2015
Testing Method: Refers to ASTM A370-14
Remark The information mentioned in the above section is provided by Client
(Exclude Date of Sample Received and Date of Testing)

Test Result:

Sample Name	Tensile Load ,
----	kN
GFRP Rock Bolt R32 Hollow Rod	333

Remark: This Test Report is an additional original report of TK-15-065757X Issued date : Sep.20, 2016

----- oOo -----

The required specification(s) offered in this test report is/are for reference only.
The conformity judgment is at the Applicant's final verdict.


Signed for and on behalf of
SGS TAIWAN Ltd.

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.